



OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 441
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: 352) 343-9473

ADDENDUM TWO
May 21, 2014

RFP 14-0630
FIRE/BURGLAR ALARM CENTRAL RECEIVER

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response. Acknowledgement may be confirmed by inclusion of a signed copy of this addendum with the initial bid or proposal response, and/or by completion of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the bid or proposal from being considered for award.

This addendum does not change the date for receipt of proposals.

Questions regarding this RFP were due May 19, 2014. The purpose of this addendum is to address question(s) received.

Question 2: Does the County need to follow UL Central Station protocols?

Answer 2: Yes, Lake County does need to meet UL Station protocols.

Question 3: Has the County considered subcontracting for central station monitoring?

Answer 3: Vendors are encouraged to submit proposals for various solutions as noted in Section 1.16 of the RFP. The County will review all proposals including alternate solutions.

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _____